Colorado Springs Fire Department

Division of the Fire Marshal Plan Review Checklist - LPG cage



Yes □ No □

Disclaimer

CSFD checklists are not intended to be all inclusive or stand-alone submittal documents. The items listed include the minimum information required to conduct an initial plan review. Please provide a separate code study document for any deviations from prescriptive code. The current Fire Code is the 2015 International Fire Code (IFC) with local CSFD amendments.

Permit Application

If a permit is required by Section 105 of the Colorado Springs Fire Code, please ensure the following items are completed/addressed in the initial submittal. Please note that each permit includes two plan reviews. Additional fees are implemented at the third review and all subsequent reviews thereafter.

1.	Are Sections 1-4 completed on the permit application?		Yes □	No □						
2.	Is Section 7 completed on the permit application?		Yes □	No □						
Site Plans Enure the following items are indicated of the floor plans for Carbon Dioxide Systems.										
1.	Is the LPG cage location shown?		Yes □	No □						
2.	Does the cage location meet the requirments of Table 6109.12		Yes □	No □						
3.	Is a 10 lb. dry chemical fire extinguisher shown? (Only for LPG quanities over 720 lbs)		Yes □	No □						
4.	Is the cage in a location subject to vehicular damage?		Yes □	No □						
5.	If yes, is vehicle impact protection shown?		Yes □	No □						
6.	Are NFPA 704 placards showm?		Yes □	No □						
7.	Are "No Smoking" signs shown?		Yes □	No □						

Cut Sheets

		161 .1			
Enure the	e tollowind	i specifications	are submitted	tor the	following items

1.	Tanks	Yes □	No □
2.	Cage	Yes □	No □